

## Minimum equipment for each room, level 1 (from CEI 64-8/3 standard)

Room	Size (m <sup>2</sup> or m)	Socket point	Light point	Radio/TV sockets
In each room that is not listed below <sup>(1)</sup> (the value between [] is the number of sockets that can be moved from a room to another, provided that the total number remains the same.	$8 < A \leq 12$ $12 < A \leq 20$ $A > 20$	4 [1] 5 [2] 6 [3]	1 1 2	1 1 1
Entrance <sup>(2)</sup>		1	1	
Kitchenette <sup>(3)</sup>		2 (1)		
Kitchen <sup>(3)</sup>		5 (2)	1	1
Laundry		3	1	
Bathroom or shower room <sup>(4)</sup>		2	2	
Toilet (WC)		1	1	
Hallway	$L \leq 5$ $L > 5$	1 2	1 2	
Balcony/terrace	$A \geq 10$	1	1	
Closet	$A \geq 1$		1	
Cellar/attic <sup>(5)</sup>		1	1	
Garage <sup>(5)</sup>		1	1	
Garden	$A \geq 10$	1	1	

<sup>(1)</sup> In the bedrooms, one less socket can be installed than indicated.

<sup>(2)</sup> If the entrance consists of a corridor longer than 5 m, a socket and a light point must be added

<sup>(3)</sup> the value between ( ) is the number of sockets that must be mounted at the worktop

<sup>(4)</sup> In bathrooms without a connection/drain for the washing machine, a single socket is sufficient

<sup>(5)</sup> The table do not apply to cellars, attics, and garage supplied by condominium services

## Minimum equipment for each room, level 2 (from CEI 64-8/3 standard)

Room	Size (m <sup>2</sup> or m)	Socket point	Light point	Radio/TV sockets
In each room that is not listed below <sup>(1)</sup>	$8 < A \leq 12$	5	2	1
	$12 < A \leq 20$	7	2	1
	$A > 20$	8	3	1
Entrance <sup>(2)</sup>		1	1	
Kitchenette <sup>(3)</sup>		2 (1)	1	
Kitchen <sup>(3)</sup>		6 (2)	2	1
Laundry		4	1	
Bathroom or shower room <sup>(4)</sup>		2	2	
Toilet (WC)		1	1	
Hallway	$L \leq 5$	1	1	
	$L > 5$	2	2	
Balcony/terrace	$A \geq 10$	1	1	
Closet	$A \geq 1$		1	
Cellar/attic <sup>(5)</sup>		1	1	
Garage <sup>(5)</sup>		1	1	
Garden	$A \geq 10$	1	1	

<sup>(1)</sup> In the bedrooms, one less socket can be installed than indicated.

<sup>(2)</sup> If the entrance consists of a corridor longer than 5 m, a socket and a light point must be added

<sup>(3)</sup> The value between ( ) is the number of sockets that must be mounted at the worktop

<sup>(4)</sup> In bathrooms without a connection/drain for the washing machine, a single socket is sufficient

<sup>(5)</sup> The table do not apply to cellars, attics, and garage supplied by condominium services

## Minimum equipment for each room, level 3 (from CEI 64-8/3 standard)

Room	Size (m <sup>2</sup> or m)	Socket point	Light point	Radio/TV sockets
In each room that is not listed below <sup>(1)</sup>	$8 < A \leq 12$	5	2	1
	$12 < A \leq 20$	8	3	1
	$A > 20$	10	4	1
Entrance <sup>(2)</sup>		1	1	
Kitchenette <sup>(3)</sup>		3 (2)	1	
Kitchen <sup>(3)</sup>		7 (3)	2	1
Laundry		4	1	
Bathroom or shower room <sup>(4)</sup>		2	2	
Toilet (WC)		1	1	
Hallway	$L \leq 5$	1	1	
	$L > 5$	2	2	
Balcony/terrace	$A \geq 10$	1	1	
Closet	$A \geq 1$		1	
Cellar/attic <sup>(5)</sup>		1	1	
Garage <sup>(5)</sup>		1	1	
Garden	$A \geq 10$	1	1	

<sup>(1)</sup> In the bedrooms, one less socket can be installed than indicated.

<sup>(2)</sup> If the entrance consists of a corridor longer than 5 m, a socket and a light point must be added

<sup>(3)</sup> The value between ( ) is the number of sockets that must be mounted at the worktop

<sup>(4)</sup> In bathrooms without a connection/drain for the washing machine, a single socket is sufficient

<sup>(5)</sup> The table do not apply to cellars, attics, and garage supplied by condominium services